

Table 4.2.12 Assessment of Industrial and Commercial Water Demand for the Year 2000

Category	Demand per Day (in litres)	Gross Demand (MLD)
Industrial	2000 / worker	28.2
Commercial	38.5 / person	8.6
School	27.2 / student	44.0
Hospital	1258.9 / bed	14.1
Offices	33.9 / day	63.1
Religious Institution	1.5 / person	9.5
Average		167.5

Source: DWASA (1997)